

Connect the REED wires to the NICKEL terminals.

Connect the TAMPER wires to the BRASS terminals.

The operating distance for non magnetic materials is approx. 0-15mm.

Note: Mounting on metal surfaces reduces the functionality, according to the metal type and thickness.



mailto:info@knightfireandsecurity.com

Unit 84 Seawall Road Ind. Estate Cardiff UK CF24 5TH 0 (00 44) 29 20 48 81 29 Tel: 0 (00 44) 29 20 48 91 32 Fax:

Drawing No:	A45
Drawn:	Chrís Moorman
Date:	21/06/10

All dimensions in mm Do not scale

Fixing Screws Provided

 -40° C to $+50^{\circ}$ C

White (No Suffix) Brown (Suffix B)

Colours:



[®] Knight Fire & Security Products Ltd All cases of [™] Infringement will be pursued.



